



**नवी मुंबई
महानगरपालिका**

पर्यावरण प्रयोगशाला

२ रा मजला, बहुउद्देशीय इमारत, सेक्टर क्र. २०,
बेलापूर गाव, बेलापूर तलावाच्या जवळ,
सी.बी.डी. बेलापूर, नवी मुंबई-४०० ६१४
दूरध्वनी:
ई-मेल:

**Navi Mumbai
Municipal**

Environment Laboratory

2nd Floor, Bahuuddeshiya Building, Sector
No.20, Belapur Village, Near by Belapur
Lake, C.B.D. Belapur, Navi Mumbai-400 614
Telephone:
E-mail:



Ref. No./NMMC/Env. Lab - Q215

Date: 27 May 2026

Sample ID: 17826

Water Analysis Report

Name Of the Customer: Zenith International & Petite Kids

Address: Plot No. 13 & 14, Sector-5, Airoli, Navi Mumbai.

E-mail: zenithinternationalpk@yahoo.com

Mobile No.: 8291191171

Date of receiving Sample: 25 May 2026

Sample Collected by:

Type of Water Sample: Drinking Water (Drinking Water Sample Testing)

Sample Testing Date: 25 May 2026 to 27 May 2026

Testing Parameters	Test Results	Test Standards (IS 10500:2012)
pH	7.0	6.5-8.5
Turbidity	1.1	Max. 5 NTU
Residual Chlorine	Nil	Min. 0.2 mg/L
MPN	0	0/100 ml
E-Coli	- Ve	-ve
F-Coli	- Ve	-ve

Conclusion: Test results of the sample are based on the sample submitted in the laboratory.

Remark: The Sample Is Within Limit.

This is the analysis report of the Drinking Water (Drinking Water Sample Testing) sample received to our Environment Laboratory on 27 May 2026. This further acknowledges that you have paid the charges Rs. 672/- vide Receipt No. ACC/2627/0000001753 dated 25 May 2026.

Analysed By

Pravin Ghadi

Lab Chemist, Environment Laboratory
Navi Mumbai Municipal Corporation

Checked By

Vivek Joshi

Lab Incharge, Environment Laboratory
Navi Mumbai Municipal Corporation

- End of Report -

Ruby Vykhare

PRINCIPAL
ZENITH INTERNATIONAL &
PETITE KIDS
Airoli, Navi Mumbai.